



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Oct-19	0:00:00	12-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 13.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	12-Oct-19	0:00:00	12-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	12-Oct-19	0:00:00	12-Oct-19	0:00:00	0:00:00	0.00	0.000	
4	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	51.00	1.207	
5	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	51.00	1.185	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Oct-19	00:00:00	12-Oct-19	24:00:00	24:00:00	205	4.850	Today(i.e. 13.10.2019), five SSP-RBPH M/cs are running. RBPH Unit No. 3 has stopped at 08:00 hrs. due to forced outage.
2	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	205	4.864	
3	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	206	4.888	
4	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	205	4.886	
5	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	206	4.930	
6	12-Oct-19	0:00:00	12-Oct-19	24:00:00	24:00:00	205	4.864	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		2.392	29.282	31.674
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		17.068	343.094	360.162
PREVIOUS DAY ACTUAL RUNNING HOURS		48:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		34:00:00	128:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.26 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 29469 Cusec 72 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 48430 Cusec 118 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
9015	601

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
238	500	8813	8744	39186	787



for
Obsty
13/10/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
- SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE