

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 14-Oct-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | Today(i.e. 15.10.2019), 1 CHPH M/c is running at 10:00 hrs. |
| 2 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 51.00 | 1.196 | |
| 5 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 9:30:00 | 9:30:00 | 51.00 | 0.469 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 14-Oct-19 | 00:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.856 | Today(i.e. 15.10.2019), five SSP-RBPH M/cs are running. RBPH Unit No. 3 is under outage on 14.10.2019. |
| 2 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.858 | |
| 3 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.912 | |
| 5 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.936 | |
| 6 | 14-Oct-19 | 0:00:00 | 14-Oct-19 | 24:00:00 | 24:00:00 | 206 | 4.878 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 1.665 | 24.440 | 26.105 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 20.472 | 393.614 | 414.086 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 33:30:00 | 120:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 28:00:00 | 120:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 48:00:00 | 120:00:00 | |

SSP hydrological data : at 08:00 Hrs on 15-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs) 52921 Cusec 129 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs) 37659 Cusec 92 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 6480 | 523 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|------|------|-------|----------|
| 0 | 0 | 5343 | 5353 | 32306 | 781 |



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE

Tauseef Ali
15/10
JE (EMC)