



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 01-Oct-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | Today(i.e. 02.10.2019), No CHPH M/c is running at 10:00 hrs. |
| 2 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 51.00 | 1.204 | |
| 5 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.862 | Today(i.e. 02.10.2019), Five SSP-RBPH M/cs are running. |
| 2 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.844 | |
| 3 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 206 | 4.864 | |
| 4 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 205 | 4.914 | |
| 5 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 1-Oct-19 | 0:00:00 | 1-Oct-19 | 24:00:00 | 24:00:00 | 206 | 4.896 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 1.204 | 24.380 | 25.584 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 1.204 | 24.380 | 25.584 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 24:00:00 | 120:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 120:00:00 | |

SSP hydrological data : at 08:00 Hrs on 2-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 215389 Cusec 527 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 211972 Cusec 519 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 3783 | 290 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|------|------|-------|----------|
| 206 | 173833 | 3956 | 3276 | 34863 | 784 |



for Archita Kavnige
J.E. (Elect.),
EMC, NCA
AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor , Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil