



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

**DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Oct-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 22-Oct-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Oct-19	0:00:00	22-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 23.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	22-Oct-19	0:00:00	22-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	22-Oct-19	19:30:00	22-Oct-19	24:00:00	4:30:00	50.00	0.218	
4	22-Oct-19	2:00:00	22-Oct-19	24:00:00	22:00:00	51.00	1.100	
5	22-Oct-19	0:00:00	22-Oct-19	8:00:00	8:00:00	52.00	0.395	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Oct-19	14:45:00	22-Oct-19	19:15:00	4:30:00	204	0.914	Today(i.e. 23.10.2019), 1 SSP-RBPH M/cs is running at 10:00 hrs.
2	22-Oct-19	5:15:00	22-Oct-19	10:00:00	4:45:00	204	0.962	
3	22-Oct-19	0:00:00	22-Oct-19	0:00:00	0:00:00	0	0.000	
4	22-Oct-19	15:00:00	22-Oct-19	19:30:00	4:30:00	205	0.922	
5	22-Oct-19	00:00 15:15	22-Oct-19	09:00 19:45	13:30:00	204	2.764	
6	22-Oct-19	6:00:00	22-Oct-19	24:00:00	18:00:00	205	3.658	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.713	9.220	10.933
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	33.174	522.326	555.500
PREVIOUS DAY ACTUAL RUNNING HOURS	34:30:00	45:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	30:00:00	38:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	46:30:00	

SSP hydrological data : at 08:00 Hrs on 23-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13472 Cusec 33 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14011 Cusec 34 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec.

HR	GODBOLE
5251	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
544	0	5284	6271	7740	778



AEE (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 23:20 hrs on 22.10.2019 to 07:40 hrs on 23.10.2019

Unit No.2: 23:30 hrs on 22.10.2019 to 07:45 hrs on 23.10.2019