



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 26-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 27.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0.00	0.000	
4	26-Oct-19	0:00:00	26-Oct-19	24:00:00	24:00:00	51.00	1.210	
5	26-Oct-19	0:10:00	26-Oct-19	8:00:00	7:50:00	50.00	0.373	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Oct-19	00:00:00	26-Oct-19	0:00:00	0:00:00	0	0.000	Today(i.e. 27.10.2019), No SSP-RBPH M/cs is scheduled.
2	26-Oct-19	0:00:00	26-Oct-19	24:00:00	24:00:00	205	4.858	
3	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0	0.000	
4	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0	0.000	
5	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0	0.000	
6	26-Oct-19	0:00:00	26-Oct-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.583	4.858	6.441
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	39.255	546.788	586.043
PREVIOUS DAY ACTUAL RUNNING HOURS	31:50:00	24:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13189 Cusec 32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8457 Cusec 21 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5045	497

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
521	0	4837	4425	4032	783



For *Arshita Karmange*
J. E. (Elect.)
EMC, NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor , Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.6: 20:20 hrs on 26.10.2019 to 06:50 hrs on 27.10.2019

Unit No.1: 20:10 hrs on 26.10.2019 to 06:45 hrs on 27.10.2019

Unit No.5: 23:15 hrs on 26.10.2019. Cont. till 10:00hrs on 27.10.2019

Unit No.1: 09:20 hrs on 27.10.2019. Cont. till 10:00hrs on 27.10.2019