



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 30.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0.00	0.000	
4	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0.00	0.000	
5	29-Oct-19	0:00:00	29-Oct-19	24:00:00	24:00:00	52.00	1.196	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Oct-19	00:00:00	29-Oct-19	0:00:00	0:00:00	0	0.000	Today(i.e. 30.10.2019), 1 SSP-RBPH M/c is running at 10:00 hrs.
2	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0	0.000	
3	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0	0.000	
4	29-Oct-19	0:00:00	29-Oct-19	0:00:00	0:00:00	0	0.000	
5	29-Oct-19	19:45:00	29-Oct-19	24:00:00	4:15:00	204	0.870	
6	29-Oct-19	19:30:00	29-Oct-19	24:00:00	4:30:00	205	0.918	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.196	1.788	2.984
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	43.135	548.576	591.711
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	8:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	32:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	24:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.52 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18222 Cusec 45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10843 Cusec 27 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4300	520

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
565	0	4304	4380	6463	797



नर्मदा नियंत्रण प्राधिकरण

*(Signature)*  
30/10/19  
AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG. CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 13:05 hrs on 29.10.2019 to 06:55 hrs on 30.10.2019

Unit No.1: 13:15 hrs on 29.10.2019 to 07:00 hrs on 30.10.2019

Unit No.4: 23:25 hrs on 29.10.2019 to 07:05 hrs on 30.10.2019