



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 31.10.2019), 2 CHPH M/c is running at 10:00 hrs.
2	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0.00	0.000	
4	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0.00	0.000	
5	30-Oct-19	0:00:00	30-Oct-19	24:00:00	24:00:00	52.00	1.203	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Oct-19	00:00:00	30-Oct-19	0:00:00	0:00:00	0	0.000	Today(i.e. 31.10.2019), No SSP-RBPH M/c is running at 10:00 hrs.
2	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0	0.000	
3	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0	0.000	
4	30-Oct-19	0:00:00	30-Oct-19	0:00:00	0:00:00	0	0.000	
5	30-Oct-19	0:00:00	30-Oct-19	8:15:00	8:15:00	203	1.680	
6	30-Oct-19	0:00:00	30-Oct-19	24:00:00	24:00:00	205	4.866	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.203	6.546	7.749
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	44.338	555.122	599.460
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	32:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	24:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.61 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 24117 Cusec 59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 11469 Cusec 28 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4304	565

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
510	0	5975	5813	5656	802



अ.ए. (एम.सी.)  
NCA, INDORE

*[Handwritten Signature]*  
31/10/19

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.5: 01:10 hrs on 31.10.2019 to 07:40 hrs on 31.10.2019

Unit No.4: 20:10 hrs on 30.10.2019 to 07:35 hrs on 31.10.2019