



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Oct-19	0:00:00	5-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 06.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	5-Oct-19	0:00:00	5-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	5-Oct-19	10:15:00	5-Oct-19	24:00:00	13:45:00	51.00	0.684	
4	5-Oct-19	0:00:00	5-Oct-19	1:00:00	1:00:00	50.00	0.049	
5	5-Oct-19	0:00:00	5-Oct-19	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Oct-19	00:00:00	5-Oct-19	24:00:00	24:00:00	206	4.870	Today(i.e. 06.10.2019), all six SSP- RBPH M/cs are running.
2	5-Oct-19	0:00:00	5-Oct-19	24:00:00	24:00:00	206	4.864	
3	5-Oct-19	0:00:00	5-Oct-19	24:00:00	24:00:00	204	4.858	
4	5-Oct-19	0:00:00	5-Oct-19	24:00:00	24:00:00	203	4.916	
5	5-Oct-19	0:00:00	5-Oct-19	24:00:00	24:00:00	202	4.860	
6	5-Oct-19	0:00:00	5-Oct-19	24:00:00	24:00:00	205	4.874	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.733	29.242	29.975
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	2.981	138.772	141.753
PREVIOUS DAY ACTUAL RUNNING HOURS	14:45:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	15:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 112041 Cusec 274 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 109938 Cusec 269 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3909	236

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
223	67792	4094	2491	39655	787



for
09/10/19

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNI,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE