



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Oct-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 06-Oct-19

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Oct-19	0:00:00	6-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 07.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	6-Oct-19	0:00:00	6-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	6-Oct-19	11:15:00	6-Oct-19	17:00:00	6:45:00	50.00	0.333	
4	6-Oct-19	0:00:00	6-Oct-19	0:00:00	0:00:00	0.00	0.000	
5	6-Oct-19	9:00:00	6-Oct-19	24:00:00	15:00:00	51.00	0.745	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Oct-19	00:00:00	6-Oct-19	24:00:00	24:00:00	206	4.864	Today(i.e. 07.10.2019), all six SSP-RBPH M/cs are running.
2	6-Oct-19	0:00:00	6-Oct-19	24:00:00	24:00:00	205	4.874	
3	6-Oct-19	0:00:00	6-Oct-19	24:00:00	24:00:00	205	4.868	
4	6-Oct-19	0:00:00	6-Oct-19	24:00:00	24:00:00	206	4.922	
5	6-Oct-19	0:00:00	6-Oct-19	24:00:00	24:00:00	203	4.876	
6	6-Oct-19	00:00:45	6-Oct-19	00:26:24:00	19:41:00	206	4.024	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		1.078	28.428	29.506
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		4.059	167.200	171.259
PREVIOUS DAY ACTUAL RUNNING HOURS		21:45:00	139:41:00	
TODAY'S DC (Schedule) Planned (in Hours)		33:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Oct-19

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 138.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 103357 Cusec 253 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 102570 Cusec 251 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4094	223

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
409	55133	5812	6789	40648	787



for  
AEE/EMC  
07/10/19

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil