



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Oct-19	0:00:00	7-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 08.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	7-Oct-19	0:00:00	7-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	7-Oct-19	0:00:20:35	7-Oct-19	9:00:24:00	12:25:00	51.00	0.611	
4	7-Oct-19	0:00:00	7-Oct-19	0:00:00	0:00:00	0.00	0.000	
5	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	51.00	1.199	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Oct-19	00:00:00	7-Oct-19	24:00:00	24:00:00	205	4.854	Today(i.e. 08.10.2019), all six SSP-RBPH M/cs are running.
2	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	205	4.860	
3	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	206	4.884	
4	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	206	4.914	
5	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	206	4.912	
6	7-Oct-19	0:00:00	7-Oct-19	24:00:00	24:00:00	206	4.886	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.810	29.310	31.120
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	5.869	196.510	202.379
PREVIOUS DAY ACTUAL RUNNING HOURS	36:25:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	34:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 81288 Cusec 199 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 71284 Cusec 174 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5812	409

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
508	25083	6667	6542	39659	789



for. Tausif A...
08/10
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor , Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Running Detail: Nil