



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Oct-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 08-Oct-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Oct-19	0:00:00	8-Oct-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.10.2019), 1 CHPH M/c is running at 10:00 hrs.
2	8-Oct-19	0:00:00	8-Oct-19	0:00:00	0:00:00	0.00	0.000	
3	8-Oct-19	0:00:00	8-Oct-19	10:00:00	10:00:00	50.00	0.487	
4	8-Oct-19	11:30 18:30	8-Oct-19	11:50 24:00	5:50:00	53.00	0.277	
5	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	50.00	1.176	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Oct-19	00:00:00	8-Oct-19	24:00:00	24:00:00	205	4.832	Today(i.e. 09.10.2019), all six SSP-RBPH M/cs are running.
2	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	204	4.848	
3	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	206	4.858	
4	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	206	4.894	
5	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	205	4.890	
6	8-Oct-19	0:00:00	8-Oct-19	24:00:00	24:00:00	205	4.860	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	1.940	29.182	31.122
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	7.809	225.692	233.501
PREVIOUS DAY ACTUAL RUNNING HOURS	39:50:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	34:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Oct-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.49 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 77401 Cusec 189 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 66076 Cusec 162 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
8765	508

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
479	17750	7585	8455	39871	794



AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet). NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil