



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 30-Sep-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 50.00 | 1.194 | Today (i.e. 01.10.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.196 | |
| 3 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 15.00 | 0.340 | |
| 4 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.207 | |
| 5 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.199 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|---|
| 1 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 206 | 4.820 | Today(i.e. 01.10.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs. |
| 2 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 205 | 4.810 | |
| 3 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 205 | 4.832 | |
| 4 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 205 | 4.848 | |
| 5 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 201 | 4.756 | |
| 6 | 30-Sep-20 | 0:00:00 | 30-Sep-20 | 24:00:00 | 24:00:00 | 206 | 4.832 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 5.136 | 28.898 | 34.034 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 107.475 | 774.374 | 881.849 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 120:00:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 120:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 120:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 1-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 80209 Cusec 196.24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 101194 Cusec 247.58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 20676 | 612 |

AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 611 | 38149 | 21094 | 19890 | 43155 | 555 |



जन भद्र - जन सदा

for *Aochita Kanungo*
J.E. (Elect.),
01.10.2020

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil