



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 09-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Oct-20	0:00:00	9-Oct-20	24:00:00	24:00:00	51.00	1.202	Today (i.e. 10.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	9-Oct-20	0:00:00	9-Oct-20	24:00:00	24:00:00	50.00	1.198	
3	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	9-Oct-20	0:00:00	9-Oct-20	24:00:00	24:00:00	51.00	1.198	
5	9-Oct-20	0:00:00	9-Oct-20	24:00:00	24:00:00	50.00	1.194	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	Today(i.e. 10.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	
3	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	
4	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	
5	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	
6	9-Oct-20	0:00:00	9-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.792	0.000	4.792
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	44.839	58.038	102.877
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.01 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20716 Cusec 50.68 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18789 Cusec 45.97 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20709	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	20458	18789	0	661



for Anchita Kawange
J.E. (Elect.)
10.10.2020

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 19:00 hrs on 09.10.2020 to 06:10 Hrs on 10.10.2020.

Unit No.6: 18:45 hrs on 09.10.2020 to 06:15 Hrs on 10.10.2020.

AEE (EMC)
NCA, INDORE