



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Oct-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 10-Oct-20

(CHPH 5X50 MW)

| Unit No. | START     |                | STOP      |                | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS  |
|----------|-----------|----------------|-----------|----------------|-------------|----------------|-------------------|--|
| 1        | 10-Oct-20 | 0:00:00        | 10-Oct-20 | 24:00:00       | 24:00:00    | 51.00          | 1.198             | Today (i.e. 11.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2        | 10-Oct-20 | 00:00<br>22:50 | 10-Oct-20 | 22:34<br>24:00 | 23:44:00    | 51.00          | 1.179             |  |
| 3        | 10-Oct-20 | 0:00:00        | 10-Oct-20 | 0:00:00        | 0:00:00     | 0.00           | 0.000             |  |
| 4        | 10-Oct-20 | 0:00:00        | 10-Oct-20 | 24:00:00       | 24:00:00    | 51.00          | 1.214             |  |
| 5        | 10-Oct-20 | 0:00:00        | 10-Oct-20 | 24:00:00       | 24:00:00    | 51.00          | 1.201             |  |

(RBPH 6X200 MW)

| Unit No. | START     |         | STOP      |         | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS   |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|---|
| 1        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             | Today(i.e. 11.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. |
| 2        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 3        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 4        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 5        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |
| 6        | 10-Oct-20 | 0:00:00 | 10-Oct-20 | 0:00:00 | 0:00:00     | 0              | 0.000             |   |

|  | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs)                 | 4.792           | 0.000           | 4.792          |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs)   | 49.631          | 58.038          | 107.669        |
| PREVIOUS DAY ACTUAL RUNNING HOURS        | 95:44:00        | 0:00:00         |                |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00        | 0:00:00         |                |
| DAY AHEAD (TOMMORROW) DC (in Hours)      | 96:00:00        | 0:00:00         |                |

SSP hydrological data : at 08:00 Hrs on 11-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.10 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30707 Cusec 75.13 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18639 Cusec 45.60 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR    | GODBOLE |
|-------|---------|
| 19987 | 0       |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR    | CHPH  | RBPH | Ev. Loss |
|---------|-----------|-------|-------|------|----------|
| 607     | 0         | 19901 | 18639 | 0    | 663      |



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 18:15 hrs on 10.10.2020 to 06:50 Hrs on 11.10.2020.

Unit No.5: 18:25 hrs on 10.10.2020 to 06:45 Hrs on 11.10.2020.

AEE (EMC)  
NCA, INDORE

*Handwritten signature and date: 11/10/20*