



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 11-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Oct-20	0:00:00	11-Oct-20	24:00:00	24:00:00	51.00	1.199	Today (i.e. 12.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	11-Oct-20	0:00:00	11-Oct-20	24:00:00	24:00:00	51.00	1.208	
3	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	11-Oct-20	0:00:00	11-Oct-20	24:00:00	24:00:00	51.00	1.218	
5	11-Oct-20	0:00:00	11-Oct-20	24:00:00	24:00:00	51.00	1.200	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	Today (i.e. 12.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	
3	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	
4	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	
5	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	
6	11-Oct-20	0:00:00	11-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.825	0.000	4.825
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	54.456	58.038	112.494
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.12 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 21928 Cusec 53.65 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18730 Cusec 45.82 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19567	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
608	0	19567	18730	0	665



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.1: 18:45 hrs on 11.10.2020 to 06:45 Hrs on 12.10.2020.

Unit No.6: 18:50 hrs on 11.10.2020 to 06:50 Hrs on 12.10.2020

AEE (EMC)
NCA, INDORE

Tanuj A. K. Patil