



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 19-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Oct-20	0:00:00	19-Oct-20	24:00:00	24:00:00	51.00	1.206	Today (i.e. 20.10.2020), 2 SSP-CHPH M/c is running at 10:00 hrs.
2	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0.00	0.000	
3	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0.00	0.000	
5	19-Oct-20	20:00:00	19-Oct-20	24:00:00	4:00:00	50.00	0.196	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	Today (i.e. 20.10.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	
3	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	
4	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	
5	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	
6	19-Oct-20	0:00:00	19-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.402	0.000	1.402
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	73.388	58.038	131.426
PREVIOUS DAY ACTUAL RUNNING HOURS	28:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.79 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18992 Cusec 46.47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6902 Cusec 16.89 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4355	511

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	6358	6902	0	687



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.4: 18:25 hrs on 19.10.2020 to 06:40 Hrs on 20.10.2020.

Unit No.6: 18:40 hrs on 19.10.2020 to 06:45 Hrs on 20.10.2020.

AEE (EMC)
NCA, INDORE

Taseef Ali
JEE(EMC)
20/10/2020