



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	20-Oct-20	0:00:00	20-Oct-20	24:00:00	24:00:00	51.00	1.206	Today (i.e. 21.10.2020), 2 SSP-CHPH M/c are running at 10:00 hrs.
2	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0.00	0.000	
3	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	20-Oct-20	16:00:00	20-Oct-20	24:00:00	8:00:00	51.00	0.405	
5	20-Oct-20	0:00:00	20-Oct-20	12:00:00	12:00:00	50.00	0.591	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	Today(i.e. 21.10.2020), 0 SSP-RBPH M/c is running at 10:00 hrs.
2	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	
3	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	
4	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	
5	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	
6	20-Oct-20	0:00:00	20-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.202	0.000	2.202
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	75.590	58.038	133.628
PREVIOUS DAY ACTUAL RUNNING HOURS	44:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	48:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 21-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.84 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15700 Cusec 38.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 8675 Cusec 21.22 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6358	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	9436	8675	0	689



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasore, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.6: 23:15 hrs on 20.10.2020 to 07:10 Hrs on 21.10.2020.

Unit No.4: 23:30 hrs on 20.10.2020 to 07:05 Hrs on 21.10.2020.

AEE (EMC)
NCA, INDORE

Handwritten signature and date: 21/10/2020