



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Oct-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 23-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 24.10.2020), 3 SSP-CHPH M/c are running at 10:00 hrs.
2	23-Oct-20	0:00:00	23-Oct-20	24:00:00	24:00:00	50.00	1.196	
3	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	23-Oct-20	0:00:00	23-Oct-20	24:00:00	24:00:00	51.00	1.220	
5	23-Oct-20	0:00:00	23-Oct-20	24:00:00	24:00:00	50.00	1.192	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Oct-20	19:15:00	23-Oct-20	24:00:00	4:45:00	204	1.018	Today(i.e. 24.10.2020), 0 SSP-RBPH M/c is running at 10:30 hrs.
2	23-Oct-20	19:00:00	23-Oct-20	24:00:00	5:00:00	205	0.950	
3	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0	0.000	
4	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0	0.000	
5	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0	0.000	
6	23-Oct-20	0:00:00	23-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.608	1.968	5.576
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	85.273	60.006	145.279
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	9:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	42:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	33:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.83 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13034 Cusec 31.89 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22480 Cusec 55.00 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14261	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
599	0	13417	13764	8716	691



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasore, Dhule-1, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Details:

Unit No.4: 03:10 hrs on 24.10.2020 to 06:40 Hrs on 24.10.2020.

Unit No.6: 03:15 hrs on 24.10.2020 to 06:45 Hrs on 24.10.2020.

AEE (EMC)  
NCA, INDORE

*Tauseef Akh*  
*24/10/2020*  
*JE (EMC)*