



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 02-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	50.00	1.198	Today (i.e. 03.10.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	50.00	1.194	
3	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	14.00	0.335	
4	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	51.00	1.203	
5	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	51.00	1.192	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Oct-20	0:00:00	2-Oct-20	23:15:00	23:15:00	205	4.730	Today (i.e. 03.10.2020), 0 SSP-RBPB M/cs are running at 10:00 hrs.
2	2-Oct-20	0:00:00	2-Oct-20	23:00:00	23:00:00	205	4.678	
3	2-Oct-20	0:00:00	2-Oct-20	23:45:00	23:45:00	205	4.842	
4	2-Oct-20	0:00:00	2-Oct-20	24:00:00	24:00:00	205	4.908	
5	2-Oct-20	0:00:00	2-Oct-20	22:45:00	22:45:00	205	4.652	
6	2-Oct-20	0:00:00	2-Oct-20	23:30:00	23:30:00	206	4.798	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	5.122	28.608	33.730
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	10.249	58.038	68.287
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	140:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.97 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 44964 Cusec 110.01 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 50639 Cusec 123.89 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
22477	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	2072	22366	19893	28674	661

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SSP-Asoj is under Emergency Outage.

3. SCO Mode Running Detail: Nil



जल नियंत्रण प्राधिकरण

जल संचालन - जल सुरक्षा

AEE (EMC)
NCA, INDORE

for Architects, Engineers (Electrical)
3.10.2020