



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Oct-20	0:00:00	3-Oct-20	24:00:00	24:00:00	51.00	1.206	Today (i.e. 04.10.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	3-Oct-20	0:00:00	3-Oct-20	24:00:00	24:00:00	50.00	1.198	
3	3-Oct-20	0:00:00	3-Oct-20	24:00:00	24:00:00	14.00	0.338	
4	3-Oct-20	0:00:00	3-Oct-20	24:00:00	24:00:00	50.00	1.208	
5	3-Oct-20	0:00:00	3-Oct-20	24:00:00	24:00:00	51.00	1.193	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	Today (i.e. 04.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	
3	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	
4	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	
5	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	
6	3-Oct-20	0:00:00	3-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.143	0.000	5.143
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.392	58.038	73.430
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 30753 Cusec 75.24 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19955 Cusec 48.82 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22054	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	22054	19955	0	661



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

3. SCO Mode Running Detail:

Unit No. 1: 22:20 Hrs on 03.10.2020 to 07:45 Hrs on 04.10.2020.

Unit No. 2: 23:10 Hrs on 03.10.2020 to 07:50 Hrs on 04.10.2020.

AEE (EMC)
NCA, INDORE

Handwritten signature and date: 04/10/20