



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Oct-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 04-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Oct-20	0:00:00	4-Oct-20	24:00:00	24:00:00	51.00	1.212	Today (i.e. 05.10.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs.
2	4-Oct-20	0:00:00	4-Oct-20	24:00:00	24:00:00	50.00	1.203	
3	4-Oct-20	0:00:00	4-Oct-20	24:00:00	24:00:00	14.00	0.335	
4	4-Oct-20	0:00:00	4-Oct-20	24:00:00	24:00:00	51.00	1.205	
5	4-Oct-20	0:00:00	4-Oct-20	24:00:00	24:00:00	51.00	1.193	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	Today(i.e. 05.10.2020), 0 SSP-RBPB M/cs are running at 10:00 hrs.
2	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	
3	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	
4	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	
5	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	
6	4-Oct-20	0:00:00	4-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	5.148	0.000	5.148
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	20.540	58.038	78.578
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.07 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 23150 Cusec 56.64 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19953 Cusec 48.82 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22054	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	0	21896	19953	0	663



Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

3. SCO Mode Running Detail:

Unit No.1: 19:45 hrs on 04.10.2020 to 06:50 Hrs on 05.10.2020.

Unit No.6: 19:55 hrs on 04.10.2020 to 06:55 Hrs on 05.10.2020

*[Signature]*  
AEE (EMC)  
NCA, INDORE