



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Oct-20	0:00:00	5-Oct-20	24:00:00	24:00:00	51.00	1.210	Today (i.e. 06.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	5-Oct-20	0:00:00	5-Oct-20	24:00:00	24:00:00	51.00	1.200	
3	5-Oct-20	0:00:00	5-Oct-20	17:00:00	17:00:00	15.00	0.238	
4	5-Oct-20	0:00:00	5-Oct-20	24:00:00	24:00:00	51.00	1.202	
5	5-Oct-20	0:00:00	5-Oct-20	24:00:00	24:00:00	50.00	1.196	

(RBPB 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	Today(i.e. 06.10.2020), 0 SSP-RBPB M/cs are running at 10:00 hrs.
2	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	
3	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	
4	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	
5	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	
6	5-Oct-20	0:00:00	5-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	5.046	0.000	5.046
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	25.586	58.038	83.624
PREVIOUS DAY ACTUAL RUNNING HOURS	113:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.02 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13559 Cusec 33.17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 19232 Cusec 47.05 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21896	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss
0	0	20595	19232	0	663



जल सार्वजनिक - जल सेवा

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 & Raj-2 lines are in service.

3. SCO Mode Running Detail:

Unit No.1: 21:10 hrs on 05.10.2020 to 05:40 Hrs on 06.10.2020.

Unit No.6: 21:25 hrs on 05.10.2020 to 05:45 Hrs on 06.10.2020.

AEE (EMC)
NCA, INDORE

Handwritten signature and date:
6/10/2020
AEE (EMC)