



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Oct-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 06-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Oct-20	0:00:00	6-Oct-20	24:00:00	24:00:00	51.00	1.208	Today (i.e. 07.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	6-Oct-20	0:00:00	6-Oct-20	24:00:00	24:00:00	51.00	1.205	
3	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	6-Oct-20	0:00:00	6-Oct-20	24:00:00	24:00:00	51.00	1.207	
5	6-Oct-20	0:00:00	6-Oct-20	24:00:00	24:00:00	50.00	1.195	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	Today (i.e. 07.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	
3	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	
4	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	
5	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	
6	6-Oct-20	0:00:00	6-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.815	0.000	4.815
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	30.401	58.038	88.439
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Oct-20
DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.99 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15753 Cusec 38.54 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18893 Cusec 46.22 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20595	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	20401	18893	0	661



for Archita Kamnagar
J.E. (ELECT),
7-10-2020

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.4: 20:15 hrs on 06.10.2020 to 05:35 Hrs on 07.10.2020.

Unit No.5: 20:30 hrs on 06.10.2020 to 05:40 Hrs on 07.10.2020.

AEE (EMC)
NCA, INDORE