



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Oct-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 08-Oct-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Oct-20	0:00:00	8-Oct-20	24:00:00	24:00:00	51.00	1.206	Today (i.e. 09.10.2020), 4 SSP-CHPH M/cs are running at 10:00 hrs.
2	8-Oct-20	0:00:00	8-Oct-20	24:00:00	24:00:00	51.00	1.202	
3	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0.00	0.000	
4	8-Oct-20	0:00:00	8-Oct-20	24:00:00	24:00:00	51.00	1.209	
5	8-Oct-20	0:00:00	8-Oct-20	24:00:00	24:00:00	50.00	1.198	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	Today (i.e. 09.10.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	
3	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	
4	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	
5	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	
6	8-Oct-20	0:00:00	8-Oct-20	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.815	0.000	4.815
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	40.047	58.038	98.085
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Oct-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.00 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14396 Cusec 35.22 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18802 Cusec 46.00 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
NA	NA

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	20095	18802	0	662



जल नियंत्रण प्राधिकरण

for Archita Kamnaga  
S.E. (Elect.)  
9.10.2020

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail:

Unit No.2: 00:10 hrs on 09.10.2020 to 05:55 Hrs on 09.10.2020.

Unit No.1: 02:15 hrs on 09.10.2020 to 05:50 Hrs on 09.10.2020.

AEE (EMC)  
NCA, INDORE