



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 09-Sep-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | Today(i.e. 10.09.2019), 5 CHPH M/c are running at 10:15 hrs. |
| 2 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 51.00 | 1.205 | |
| 3 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 50.00 | 1.188 | |
| 4 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 51.00 | 1.203 | |
| 5 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 50.00 | 1.192 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 192 | 4.516 | Today(i.e. 10.09.2019), All six SSP-RBPH M/cs are running. |
| 2 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 191 | 4.476 | |
| 3 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 192 | 4.550 | |
| 4 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 190 | 4.508 | |
| 5 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 188 | 4.496 | |
| 6 | 9-Sep-19 | 0:00:00 | 9-Sep-19 | 24:00:00 | 24:00:00 | 193 | 4.512 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 4.788 | 27.058 | 31.846 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 41.496 | 249.798 | 291.294 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 96:00:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 10-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.41 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 662335 Cusec 1620 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 614961 Cusec 1505 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 19050 | 436 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|--------|-------|-------|----------|
| 383 | 553135 | 614961 | 20091 | 41735 | 492 |



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE

Tanuj Aw
10/09
JE (EMC)