

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 10-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Sep-19	10:15:00	10-Sep-19	15:00:00	4:45:00	50.00	0.237	Today(i.e. 11.09.2019), 4 CHPH M/c are running at 10:00 hrs.
2	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	51.00	1.204	
3	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	51.00	1.193	
4	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	50.00	1.201	
5	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	51.00	1.196	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	190	4.446	Today(i.e. 11.09.2019), All six SSP-RBPH M/cs are running.
2	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	191	4.446	
3	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	193	4.500	
4	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	190	4.462	
5	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	188	4.474	
6	10-Sep-19	0:00:00	10-Sep-19	24:00:00	24:00:00	193	4.486	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		5.031	26.814	31.845
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		46.527	276.612	323.139
PREVIOUS DAY ACTUAL RUNNING HOURS		100:45:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.84 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 806338 Cusec 1973 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 751350 Cusec 1838 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19021	383

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
428	690974	19053	18846	41530	503



(Signature)
11/9/19
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP: Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.
2. SCO Mode Running Detail: Nil