



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 19-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	51.00	1.190	Today(i.e. 20.09.2019), 4 CHPH M/c are running at 10:00 hrs.
2	19-Sep-19	12:50 22:35	19-Sep-19	13:15 24:00	1:50:00	32.00	0.055	
3	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	51.00	1.187	
4	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	51.00	1.209	
5	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	51.00	1.191	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	206	4.896	Today(i.e. 20.09.2019), All six SSP-RBPH M/cs are running.
2	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	207	4.898	
3	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	205	4.894	
4	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	206	4.914	
5	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	206	4.914	
6	19-Sep-19	0:00:00	19-Sep-19	24:00:00	24:00:00	206	4.900	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.832	29.416	34.248
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	92.637	527.298	619.935
PREVIOUS DAY ACTUAL RUNNING HOURS	97:50:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 279373 Cusec 684 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 277527 Cusec 679 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19039	404

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
442	217729	17592	17385	42413	530



Arochita Kharungo
J.E. (Elect.)
EMC, NCA
20-09-19

P
too

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil