



સર્દાર સારોવાર પ્રદિકરણ  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Sep-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 22-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	51.00	1.188	Today(i.e. 23.09.2019), 5 CHPH M/c are running at 10:00 hrs.
2	22-Sep-19	00:00 20:05	22-Sep-19	11:30 24:00	15:25:00	30.00	0.230	
3	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	50.00	1.185	
4	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	51.00	1.199	
5	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	51.00	1.183	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	206	4.874	Today(i.e. 23.09.2019), All six SSP-RBPH M/cs are running.
2	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	206	4.886	
3	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	207	4.906	
4	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	206	4.928	
5	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	205	4.902	
6	22-Sep-19	0:00:00	22-Sep-19	24:00:00	24:00:00	207	4.916	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)					4.985	29.412	34.397
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					107.528	615.352	722.880
PREVIOUS DAY ACTUAL RUNNING HOURS					111:25:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)					120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.28 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 208641 Cusec 510 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 208113 Cusec 509 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19023	501

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
458	148330	18789	17899	41884	529



for  
AEE (EMC)  
23/09/19

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil