



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Sep-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 25-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	51.00	1.206	Today(i.e. 26.09.2019), 5 CHPH M/c are running at 10:00 hrs.
2	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	15.00	0.361	
3	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	51.00	1.202	
4	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	51.00	1.197	
5	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	52.00	1.206	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	207	4.880	Today(i.e. 26.09.2019), All six SSP-RBPH M/cs are running.
2	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	206	4.868	
3	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	207	4.900	
4	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	207	4.940	
5	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	205	4.890	
6	25-Sep-19	0:00:00	25-Sep-19	24:00:00	24:00:00	207	4.908	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.172	29.386	34.558
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	122.989	703.512	826.501
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 26-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.29 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 169976 Cusec 416 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 164183 Cusec 402 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18730	438

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
512	103941	18969	18655	41587	529



उत्सव जल - उत्सव संघ

AEE (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil