



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Sep-19

ISSUE TIME: 10:00 Hrs

FOR DATE: 03-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Sep-19	10:00:00	3-Sep-19	17:30:00	7:30:00	51.00	0.377	Today(i.e. 04.09.2019), 2CHPH M/c are running at 10:00 hrs.
2	3-Sep-19	0:00:00	3-Sep-19	13:15:00	13:15:00	51.00	0.658	
3	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	52.00	1.197	
4	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	51.00	1.204	
5	3-Sep-19	0:00:00	3-Sep-19	20:00:00	20:00:00	52.00	0.997	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	200	4.740	Today(i.e. 04.09.2019), All six SSP-RBPH M/cs are running.
2	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	200	4.736	
3	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	201	4.718	
4	3-Sep-19	0:00:00	3-Sep-19	23:45:00	23:45:00	201	4.718	
5	3-Sep-19	0:00:00	3-Sep-19	21:50:00	21:50:00	201	4.338	
6	3-Sep-19	0:00:00	3-Sep-19	24:00:00	24:00:00	202	4.740	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.433	27.990	32.423
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	14.051	85.062	99.113
PREVIOUS DAY ACTUAL RUNNING HOURS	88:45:00	141:35:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 112291 Cusec 275 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 56074 Cusec 137 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22021	405

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	Overflow
430	6862	15569	15711	33501	465	6862



जल बचत - जल संकट

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil