



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 05-Sep-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|----------------|----------|----------------|-------------|----------------|-------------------|--|
| 1 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 14:50:00 | 14:50:00 | 51.00 | 0.739 | Today(i.e. 06.09.2019), 3 CHPH M/c are running at 10:00 hrs. |
| 2 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 51.00 | 1.205 | |
| 3 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 50.00 | 1.195 | |
| 4 | 5-Sep-19 | 15:10:00 | 5-Sep-19 | 24:00:00 | 8:50:00 | 50.00 | 0.431 | |
| 5 | 5-Sep-19 | 00:00 11:30 | 5-Sep-19 | 05:00 24:00 | 17:30:00 | 50.00 | 0.865 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 203 | 4.606 | Today(i.e. 06.09.2019), All six SSP-RBPH M/cs are running. |
| 2 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 202 | 4.578 | |
| 3 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 203 | 4.588 | |
| 4 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 203 | 4.616 | |
| 5 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 200 | 4.578 | |
| 6 | 5-Sep-19 | 0:00:00 | 5-Sep-19 | 24:00:00 | 24:00:00 | 203 | 4.608 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 4.435 | 27.574 | 32.009 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 22.423 | 137.660 | 160.083 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 89:10:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 6-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.75 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 428412 Cusec 1048 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 414463 Cusec 1014 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 15772 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss | Overflow |
|---------|-----------|-------|-------|-------|----------|----------|
| 0 | 355078 | 19007 | 17671 | 41714 | 478 | 355078 |



for Shumbe
6/9/19
JG, AEE/NCA

AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: Nil