



अफात नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 07-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Sep-19	11:30:00	7-Sep-19	14:30:00	3:00:00	50.00	0.144	Today(i.e. 08.09.2019), 4 CHPH M/c are running at 10:00 hrs.
2	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	51.00	1.203	
3	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	51.00	1.198	
4	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	51.00	1.200	
5	7-Sep-19	00:00:00 16:00	7-Sep-19	11:35:00 24:00	19:35:00	50.00	0.964	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	206	4.786	Today(i.e. 08.09.2019), All six SSP-RBPH M/cs are running.
2	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	204	4.782	
3	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	205	4.790	
4	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	204	4.824	
5	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	205	4.848	
6	7-Sep-19	0:00:00	7-Sep-19	24:00:00	24:00:00	205	4.790	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.709	28.820	33.529
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	31.920	194.570	226.490
PREVIOUS DAY ACTUAL RUNNING HOURS	94:35:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.06 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 273133 Cusec 668 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 252375 Cusec 617 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19043	509

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
472	191652	19046	18585	42138	485 ✓



Handwritten signature: Ashwika Kanungo
J.E. (Elect)
EMC, NCA
8.9.19

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor , Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE