



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 09-Sep-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 08-Sep-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Sep-19	0:00:00	8-Sep-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 09.09.2019), 4 CHPH M/c are running at 10:00 hrs.
2	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	50.00	1.205	
3	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	51.00	1.198	
4	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	51.00	1.205	
5	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	50.00	1.180	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	200	4.694	Today(i.e. 09.09.2019), All six SSP-RBPH M/cs are running.
2	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	200	4.676	
3	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	201	4.680	
4	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	200	4.714	
5	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	200	4.722	
6	8-Sep-19	0:00:00	8-Sep-19	24:00:00	24:00:00	200	4.684	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.788	28.170	32.958
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	36.708	222.740	259.448
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 9-Sep-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.04 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 388592 Cusec 951 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 390639 Cusec 956 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
19046	472

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
436	328731	19050	20406	41502	487



AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil