



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Sep-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 12-Sep-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Sep-20	0:00:00	12-Sep-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 13.09.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	12-Sep-20	00:00 12:28	12-Sep-20	12:13 24:00	23:45:00	50.00	1.188	
3	12-Sep-20	0:00:00	12-Sep-20	0:00:00	0:00:00	0.00	0.000	
4	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	51.00	1.218	
5	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	51.00	1.205	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	206	4.898	Today(i.e. 13.09.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	205	4.892	
3	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	205	4.898	
4	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	206	4.940	
5	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	204	4.926	
6	12-Sep-20	0:00:00	12-Sep-20	24:00:00	24:00:00	205	4.878	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.611	29.432	33.043
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	33.438	285.126	318.564
PREVIOUS DAY ACTUAL RUNNING HOURS	71:45:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.67 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 76093 Cusec 186.17 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 55313 Cusec 135.33 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
14496	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14397	13323	41990	507



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.
- SCO Mode Running Detail: Nil

AEE (EMC)  
NCA, INDORE

*Handwritten signature and date: 13/09/20*