



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Sep-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 14-Sep-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Sep-20	0:00:00	14-Sep-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 15.09.2020), 1 SSP-CHPH M/c is running at 10:00 hrs.
2	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	51.00	1.200	
3	14-Sep-20	0:00:00	14-Sep-20	0:00:00	0:00:00	0.00	0.000	
4	14-Sep-20	0:00:00	14-Sep-20	16:45:00	16:45:00	51.00	0.859	
5	14-Sep-20	0:00:00	14-Sep-20	16:30:00	16:30:00	51.00	0.811	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	206	4.882	Today (i.e. 15.09.2020), 2 SSP-RBPH M/cs are running at 10:00 hrs.
2	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	206	4.888	
3	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	206	4.906	
4	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	206	4.930	
5	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	205	4.932	
6	14-Sep-20	0:00:00	14-Sep-20	24:00:00	24:00:00	206	4.888	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.870	29.426	32.296
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	39.918	343.998	383.916
PREVIOUS DAY ACTUAL RUNNING HOURS	57:15:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	65:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	48:00:00	52:15:00	

SSP hydrological data : at 08:00 Hrs on 15-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 65851 Cusec 161.11 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 42530 Cusec 104.05 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14397	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	7810	7764	34766	514



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.
- SCO Mode Running Detail: Nil

AEE (EMC)  
NCA, INDORE

*Tauseef Ak*  
15/09/2020