



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Sep-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-Sep-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	50.00	1.189	Today (i.e. 23.09.2020), 5 SSP-CHPH M/c is running at 10:00 hrs.
2	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	50.00	1.189	
3	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	15.00	0.350	
4	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	51.00	1.201	
5	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	51.00	1.187	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	206	4.800	Today (i.e. 23.09.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	203	4.792	
3	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	206	4.798	
4	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	201	4.820	
5	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	200	4.794	
6	22-Sep-20	0:00:00	22-Sep-20	24:00:00	24:00:00	205	4.816	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.116	28.820	33.936
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	66.358	541.802	608.160
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.78 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 130353 Cusec 318.92 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 209685 Cusec 513.01 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
19970	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
627	148569	21122	18914	42202	496



जल मयत - जल संयत

[Signature]
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE (E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

- 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.
- SCO Mode Running Detail: Nil