



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Sep-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 23-Sep-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	50.00	1.195	Today (i.e. 24.09.2020), 5 SSP-CHPH M/c is running at 10:00 hrs.
2	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	50.00	1.193	
3	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	15.00	0.350	
4	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	51.00	1.205	
5	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	51.00	1.195	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	202	4.792	Today (i.e. 24.09.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs.
2	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	202	4.796	
3	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	201	4.780	
4	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	202	4.844	
5	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	200	4.824	
6	23-Sep-20	0:00:00	23-Sep-20	24:00:00	24:00:00	202	4.816	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.138	28.852	33.990
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	71.496	570.654	642.150
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 24-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.89 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 183682 Cusec 449.39 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 169254 Cusec 414.09 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21121	627

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
616	107552	22295	19324	42378	490



[Signature]
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.
2. SCO Mode Running Detail: Nil