



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 03-Sep-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 02-Sep-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	40.00	0.957	Today (i.e. 03.09.2020), 3 SSP-CHPH M/c are running at 10:00 hrs.
2	2-Sep-20	10:00:00	2-Sep-20	24:00:00	14:00:00	50.00	0.697	
3	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	50.00	1.195	
4	2-Sep-20	0:00:00	2-Sep-20	19:00:00	19:00:00	51.00	0.961	
5	2-Sep-20	0:00:00	2-Sep-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	197	4.404	Today(i.e. 03.09.2020), 6 SSP-RBPH M/c are running at 10:00 hrs.
2	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	197	4.418	
3	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	197	4.408	
4	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	197	4.436	
5	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	192	4.406	
6	2-Sep-20	0:00:00	2-Sep-20	24:00:00	24:00:00	196	4.392	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	3.810	26.464	30.274
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	7.712	49.472	57.184
PREVIOUS DAY ACTUAL RUNNING HOURS	81:00:00	144:00:00	
TODAY's DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 3-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.88 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 319938 Cusec 782.75 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 119311 Cusec 291.90 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17307	0

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	61900	17485	15104	42307	425



for Archita Kanungo  
3.09.2020  
AEE (EMC)  
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil.