



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Sep-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 29-Sep-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.198 | Today (i.e. 30.09.2020), 5 SSP-CHPH M/cs are running at 10:00 hrs. |
| 2 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 50.00 | 1.194 | |
| 3 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 15.00 | 0.349 | |
| 4 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.211 | |
| 5 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 50.00 | 1.185 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|-----------|---------|-----------|----------|-------------|----------------|-------------------|--|
| 1 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 202 | 4.792 | Today (i.e. 30.09.2020), 6 SSP-RBPH M/cs are running at 10:00 hrs. |
| 2 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 204 | 4.778 | |
| 3 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 204 | 4.804 | |
| 4 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 202 | 4.810 | |
| 5 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 199 | 4.754 | |
| 6 | 29-Sep-20 | 0:00:00 | 29-Sep-20 | 24:00:00 | 24:00:00 | 203 | 4.802 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 5.137 | 28.740 | 33.877 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 102.339 | 745.476 | 847.815 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 120:00:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 120:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 120:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 30-Sep-20

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 135.15 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 61733 Cusec 151.03 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 166442 Cusec 407.21 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 20832 | 617 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 612 | 104283 | 20676 | 19675 | 42484 | 460 |



जल संचयन - जल संरक्षण

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. 400 kV SSP Asoj under emergency shutdown taken by SSP.

3. SCO Mode Running Detail: Nil

AEE (EMC)
NCA, INDORE