



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Sep-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Sep-20

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|----------|----------|----------|-------------|----------------|-------------------|---|
| 1 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 41.00 | 0.963 | Today (i.e. 04.09.2020), 4 SSP-CHPH M/c are running at 10:00 hrs. |
| 2 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.205 | |
| 3 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 51.00 | 1.198 | |
| 4 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 3-Sep-20 | 11:00:00 | 3-Sep-20 | 19:30:00 | 8:30:00 | 51.00 | 0.415 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 200 | 4.686 | Today(i.e. 04.09.2020), 6 SSP-RBPH M/c are running at 10:00 hrs. |
| 2 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 200 | 4.688 | |
| 3 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 199 | 4.668 | |
| 4 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 198 | 4.682 | |
| 5 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 195 | 4.594 | |
| 6 | 3-Sep-20 | 0:00:00 | 3-Sep-20 | 24:00:00 | 24:00:00 | 199 | 4.678 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 3.781 | 27.996 | 31.777 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 11.493 | 77.468 | 88.961 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 80:30:00 | 144:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 96:00:00 | 144:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 96:00:00 | 144:00:00 | |

SSP hydrological data : at 08:00 Hrs on 4-Sep-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 135.34 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 284222 Cusec 695.37 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 225488 Cusec 551.67 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|-------|---------|
| 17485 | 0 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|-------|-------|-------|----------|
| 0 | 169404 | 17457 | 14624 | 41460 | 449 |



For Anelita Karunge
4.9.2020

AEE (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 & Raj-2 lines are in service.

2. SCO Mode Running Detail: Nil.